

(Govt. Recognized)

Reg. No. : E/1471/Navsari



A B School

"A Quality Science School"

:: Managed By ::

PRAGATI VIDIDHALAKSHI CHARITABLE TRUST, NAVSARI.


At. Partapore, Po. Mogar, Chhapra - Mogar Road, Navsari 396 463 (Mo.: 82385 88844)

To whomsoever it may concern

In accordance with the amendment of Fire Safety Rules by Gujarat Government, with the order no. GH/V/9 of 2021/AGN-102021-100-LI dated 22.01.2021, and the revised notification passed on 12.01.2022, reference no. SFS/FN-85.1/55/2022 outlines that the **Fire Safety Certificates issued after the Order dated 22.01.2021 shall bear three years of validity.**

It is further certified that **A. B. School, Navsari had the fire safety certificate issued on 25.10.2021,** thereby, as per the Gujarat State Govt. rules and norms, the certificate is valid until **25.10.2024**


PRINCIPAL
A B SCHOOL
AT.PARTAPORE,TA.DI.NAVSARI.


PRESIDENT
PRAGATI VIDIDHLAKSHI
CHARITABLE TRUST,NAVSARI

**Copy of the Fire Safety Certificate issued by Regional Fire Officer,
Surat**



WE SERVE TO SAVE
REGIONAL FIRE OFFICER
GUJARAT STATE FIRE PREVENTION SERVICES SOUTH GUJARAT
BARDOLI FIRE STATION , B/H.RAMJI MANDIR , BARDOLI
E-MAIL :- Fireofficer@gmail.com Mob No.99743-35667

No.RFO-SFPS/F.No.1776 /NOC- Educational Building

Date :-25/10/2021

FORM B13
(See sub rule (1) of rule 23)

Fire Safety Certificate

Certified That A B School | Building.A, B, C | , At. Partapore
Po.Mogar , Chhapra – Mogar Road , Navsari -396463 , Gujarat Comprised Of
Building And Having Occupancies Of Educational Building Owned/ Occupied By
A B School | Building.A, B, C | Have Complied With The Fire Prevention And
Fire Safety Requirements In Accordance With Section-18 And Verified By The
Officers Concerned Of Fire Service On Dated:-23/10/2021 In The Presence Of
Mr.Ankur Laljibhai Boda , Trustee The Building/Premises Is Fit For Occupancy
With Effect From For A Period Of (Form Date-25/10/2021 To Date-24/10/2022)
One (01) Years In Accordance With Rules And Subject To Compliance Of Any
Specific Liad By The Issuing Officer .

The administrative charge of N.O.C Rs.1000 x 01=1000/- has
been recovered vide Chalan No-849, Dated:-22/10/2021, Rs.1000 x 02=2000/-
Chalan No-859, Dated:-25/10/2021 , Inspection Charage Rs.2500 x 01=2500/- vide
Chalan No-848 , Dated:-22/10/2021 , Rs.2500 x 02=5000/- Chalan No-858,
Dated:-25/10/2021 The duration of the inspection report is valid up to (one year
from the date of issue)

Note :- This NOC Should Be Cancelled Out Immediate If Found Not Obeying Of
Any Instruction and Applicable CGDCR Act, Rules And Regulation For
Fire Noc .

Issued Date :- 25/10/2021




P.B. Gadhvi
Regional Fire Officer
Surat.

Copy to , Sarpanch Shri , Gam Panchayat Partapore ,Navsari , For Information.


PRINCIPAL
A B SCHOOL
AT.PARTAPORE,TA.DI.NAVSARI.


PRESIDENT
PRAGATI VIVIDHLAKSHI
CHARITABLE TRUST,NAVSARI

Copy of the Notification received from Urban Development and Urban Housing Department, Gandhinagar dated 22.01.2022

Notification
Urban Development and Urban Housing Department,
Sachivalaya, Gandhinagar.
Dated the 22nd January, 2021.

No.GH/V/9 of 2021/AGN-102021-100-L1 - WHEREAS the circumstances exist which renders it necessary to amend the Gujarat Fire Prevention and Life Safety Measures Rules, 2014;

AND WHEREAS circumstances exist which renders it necessary for the State Government to dispense with the power conferred by sub-section (1) of section 57 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013;

NOW THEREFORE in exercise of the powers conferred by section 57 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 read with section 14 of the Gujarat Fire Prevention and Life Safety Measures (Amendment) Ordinance, 2021 (Guj. Ord. No. 3 of 2021), the Government of Gujarat hereby makes the following rules further to amend the Gujarat Fire Prevention and Life Safety Measures Rules, 2014, namely:-

1. (1) These rules may be called the Gujarat Fire Prevention and Life Safety Measures (Amendment) Rules, 2021.
(2) They shall come into force on the date of their publication in the Official Gazette.
2. In the Gujarat Fire Prevention and Life Safety Measures Rules, 2014 (hereinafter referred to as "the said Rules"), in rule 2, for sub-rule (2), the following sub-rule shall be substituted, namely:-

"(2) The words and expressions not defined in these rules but defined in the Act, or GDCR or National Building Code of India or relevant Indian Standards or Specifications published by Bureau of Indian Standards shall have the meanings as assigned to them in the Act or GDCR or National Building Code of India or relevant Indian Standards or Specifications published by the Bureau of Indian Standards for construction and fire safety of buildings or premises and pandals."

3. In the said Rules, for rule 4, the following new rule shall be substituted, namely:-

"4. Equipment and Appliances for Fire Service

- (1) The Chief Fire Officer in Municipal Corporation area and the Director in other areas of the State shall determine the requirement of equipment and appliances for rescue, firefighting, personal protection in such numbers and with such specifications taking into consideration the apprehension of fire risk in their area for effective measures of safety and efficient response in times of emergency. The Chief Fire Officer shall submit the report in this regard to the Director every year.
- (2) The Chief Fire Officer in Municipal Corporation area and the Director in other areas of the State, with the previous sanction of the Government, shall procure equipment and appliances determined under sub-rule (1) in such manner that each fire division is adequately equipped to meet with the requirement of fire-fighting and fire safety measures and make all necessary arrangements for their upkeep and maintenance to ensure their availability to provide fire prevention and fire safety service as and when required.
- (3) The life of equipment and appliances may be as per the recommendations of the Standing Fire Advisory Council of the Ministry of Home Affairs, Government of India or of any other authority as may be authorized by the Government for this purpose."

4. In the said Rules, in rule 5, -

- (i) for sub-rule (1), the following new sub-rule shall be substituted, namely:-

"(1) The Chief Fire Officer in Municipal Corporation area and the Director in other areas of the State, shall identify the area where the establishment of a fire station is tactically advantageous to provide fire prevention and life safety measure."

- (ii) for sub-rule (4), the following new sub-rule shall be substituted, namely:-

"(4) The composition of the fire station alongwith the staff pattern and facilities to be provided by a fire station may be decided by the Chief Fire Officer in Municipal Corporation area and the Director in other area, depending upon the circumstances prevailing and apprehension of fire risk in the area."

5. In the said Rules, for rule 9, the following new rule shall be substituted, namely:-

"9. **Eligibility for Licensed Agency.**-No person or association of persons shall be eligible to apply for grant of license to act as a Licensed Agency unless he,-

- (a) possesses atleast any of the following qualifications, namely:-
- (i) Bachelor's or Master's degree in Fire or Fire & Safety or Fire & Environment, Health and Safety; or Fire Engineering from a University established or incorporated by an Act of the Parliament or a State Act in India or an educational institution declared as deemed to be a University under section 3 of the University Grants Commission Act, 1956 (3 of 1956); or
 - (ii) Advanced Diploma or Diploma or Certificate in Fire Engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India or by the Gujarat State Institute for Fire Safety Training (GSIFST), Government of Gujarat or by the Gujarat Institute of Disaster Management (GIDM), Government of Gujarat; or
 - (iii) Post Graduate Diploma or Post Diploma in Fire or Fire & Safety or Fire & Environment, Health & Safety; or Fire Engineering; or Industrial Safety or Industrial Safety & Health from a University established or incorporated by an Act of the Parliament or a State Act in India or from an educational institution declared as deemed to be a University under section 3 of the University Grants Commission Act, 1956 (3 of 1956); or
 - (iv) Fellow (FIFireE) or Member (MIFireE) or Graduate (GIFireE) of the Institution of Fire Engineers (U.K.) or the Institution of Fire Engineers (India); and
- (b) has a degree in Civil or Chemical or Mechanical or Electrical or Electronics Engineering or Architecture obtained from a University established or incorporated by an Act of the Parliament or a State Act in India or an educational institution declared as deemed to be a University under section 3 of the University Grants Commission Act, 1956 (3 of 1956); and

- (c) has during the period of 5 years immediately preceding the year of making application, experience of 3 years (2 years in case of having qualification mentioned in a(i) and (b)) in executing the work in relation to fire prevention, life safety and fire protection system; or holds a certificate of FSO specialist course awarded by the Gujarat State Institute for Fire Safety Training (GSIFST), Government of Gujarat; and
 - (d) has not been black-listed by any Government Department or authority established by a law of the State Legislature or any board or corporation or organization owned or controlled by the State Government or any other State Government."
6. In the said Rules, for rules 10 and 11, the following rules shall be substituted, namely:-

"10 Application for to act as Licensed Agency.-(1) Any person or an association of persons who intend to act as a Licensed Agency as specified under sub-section (2) of section 28 shall make an application in "Form A1" for obtaining license.

(2) The application made under sub rule (1) shall be accompanied by fees as notified by the State Government from time to time.

(3) The Applicant shall attach the following documents, namely:-

- (i) attested copy of partnership deed and power of attorney or articles of association and memorandum of association or affidavit on stamp paper in case the individual is the sole proprietor of the firm;
- (ii) certificates regarding satisfactory completion of works carried out for the required experience period.
- (iii) declaration regarding appointment of person fulfilling the requirement specified in clause (a) of rule (9);
- (iv) attested passport size photographs of partners or directors or individual proprietor and also of the professionals mentioned in clause (a) and (b) of rule 9 referred to in the application;
- (v) affidavit on appropriate stamp paper, stating that his/ her firm is not black listed by any of the departments of the State Government, local authority or any board or corporation or

organization owned or controlled by the State Government or any other State Government;

- (vi) address proof of office/ branch in Gujarat;
- (vii) list of technical staff with their qualifications; and
- (viii) such other information and/or documents as may be required by the Director.

11. License to act as Licensed Agency.- The application made under rule 10 shall be scrutinized by the Director in accordance with the rules and on being satisfied that the applicant fulfills all the criteria for grant of license to work as Licensed Agency, he shall grant the License in "Form-A2" to act as Licensed Agency subject to the following terms and conditions, namely :—

- (1) The licence shall be—
 - (a) non-transferable,
 - (b) valid for two year from the date of issue, unless suspended or cancelled earlier,
 - (c) renewable for period of two years, if so desired, before expiry of the licence.
- (2) Changes, if any, in respect of
 - (a) partners, director and/or members,
 - (b) address of the office of the Licensed Agency,

shall be forthwith reported to the Authority issuing the licence.

(3) The Licensed Agency shall always keep the work, executed or being executed by it, open for inspection by the Director or the Regional Fire Officer or Chief Fire Officer or any fire officer authorised by the Director or the Regional Fire Officer or the Chief Fire Officer.

(4)The Licensed Agency shall have office / branch in the State of Gujarat."

7. In the said Rules, for rule 14, the following new rule shall be substituted, namely:-

"14. **Certificates to be issued by a licensed agency.**-(1) A certificate regarding the compliance of the fire prevention, life safety and fire protection measures in a building or a part thereof as specified in the THIRD SCHEDULE, may be issued by a Licensed Agency in "Form-B1".

(2) During the period of validity of the Fire Safety Certificate i.e. from the date of issuance till the first renewal of the same, the Licensed Agency shall give an annual declaration in "Form-B2" stating that the fire prevention, life safety and fire protection measures provided in the building or premises are operational, in good repair and efficient condition as specified in sub-section (2) of section 29 of the Act. This declaration shall be submitted to the Regional Fire officer or the Chief Fire officer not later than 15 days every year on completion of first and second year from the date of issue of fire safety certificate."

8. In the said Rules, for rule 21, the following new rule shall be substituted, namely:-

"21. **Appointment of Fire Safety Officer.**-(1) For the purpose of effective fire prevention, life safety and fire protection measures during the occupancy of the building and to get the fire safety certificate renewed, every owner or occupier shall appoint a fire safety officer, two months prior to expiry of fire safety certificate issued under section 21, having prescribed qualifications, experience and training and thereafter shall send the compliance report to that effect in "Form-B11" to the Regional Fire Officer or the Chief Fire Officer.

(2) Fire safety officer shall be enrolled by the Director after successful completion of the prescribed training and shall be issued the enrolment certificate in "Form-B12".

(3) In case of failure to appoint a fire safety officer as specified in sub-rule (1), the Regional Fire Officer or the Chief Fire Officer shall, if it is considered to do so, communicate to the relevant

authority to take appropriate action for the discontinuance of the use or closure of the building or premises or part thereof, as the case may be.

(4) The classification of buildings or premises, the qualifications, experience, type of training and duties of different categories of the Fire Safety Officer shall be as specified in the FOURTH SCHEDULE."

9. In the said Rules, in rule 22, for sub-rule (1), the following new sub-rule shall be substituted, namely:-

"(1) The minimum standards for fire prevention, life safety and fire protection for buildings or premises required under sub-section (2) of section 18 of the Act, as provided in the GDCR or National Building Code of India, shall mutatis-mutandis apply in the following matters, namely:-"

10. In the said Rules, in sub-rule 23, for sub-rule (2), the following new sub-rule shall be substituted, namely:-

"(2) The application for grant of Fire Safety Certificate shall be made to the Regional Fire Officer or the Chief Fire Officer in "Form-B14" and shall be accompanied with a certificate from the Licensed Agency or architect on record or engineer on record or structural engineer on record and owner or occupiers to the effect that all the fire prevention, life safety and fire protection measures as required under rule 22 have been incorporated in the building or premises."

11. In the said Rules, for rule 24, the following new rule shall be substituted, namely:-

"24. **Duration of Fire Safety Certificate.**-The fire safety certificate issued under rule 23 unless sooner cancelled shall be valid for a period of 3 years from the date of issue:

as Provided that the Regional Fire Officer or the Chief Fire Officer, the case may be, may reduce the period after recording the reasons thereof."

12. In the said Rules, for rule 25, the following new rule shall be substituted, namely:-

“25. **Renewal of Fire Safety Certificate.**- The Fire Safety Officer shall inspect the building or premises for which he is appointed under Rule 21, to verify the compliance of relevant rules and regulations and then issue a Fire Safety Certificate Renewal in "Form-B13.3" valid for a period of two years from the date of issue and for the same period thereafter.”

13. In the said Rules, in rule 26,

(i) for sub-rules (1) and (2), the following new sub-rules shall be substituted, namely:-

“(1) The owner or the occupier of the building or premises, as the case may be, shall maintain the fire prevention, life safety and fire protection measures provided in the building or premises at all times in best repairs for use by the occupants or members of Fire Service or both in the event of an outbreak of fire.

(2) The owner or occupier of the building or premises and the Fire Safety Officer appointed under section 12 of the Act, as the case may be, shall declare, after inspection every six months in "Form-B15" that fire prevention, life safety and fire protection measures provided in the building or premises are operational, in place and in best repairs.”

(ii) after sub-rule (4), the following new sub-rule shall be added, namely:-

“(5) In case of building or premises having more than one occupier, the association or the society of the occupiers shall be responsible for maintaining the fire safety measures as provided in the rules.”

14. In the said Rules, in rule 27, for sub-rule (2), the following new sub-rule shall be substituted, namely:-

“(2) The promoter, organizer or the owner or occupier shall be required to provide and maintain the measures specified in sub-rule (1).”

15. In the said Rules, for rule 32, the following new rule shall be substituted, namely:-

"32. **Training Charges.**- The trainees including Fire Safety Officers, shall pay at the time of admission, training charges as notified by the State Government, to the Principal, Gujarat State Institute for Fire Safety Training (GSIFST):

Provided that, the trainees on the roll of State Fire Service shall not be liable to pay training charges."

16. In the said Rules, in rule 37, for the words "after the institution of prosecution by the officer specified in column (2)", the words "after the institution of prosecution by the officer specified in column (1)" shall be substituted.

17. In the said Rules, for the FIRST SCHEDULE, the following schedule shall be substituted, namely:-

FIRST SCHEDULE

(See Rule 3)

Qualifications for the appointment of Nominated Officer

No person shall be eligible for the appointment as Nominated Officer unless he/she possesses atleast any of the following qualifications, namely:-

- (i) Bachelor's or Master's degree in Fire or Fire & Safety or Fire & Environment, Health & Safety; or Fire Engineering from a University established or incorporated by an Act of the Parliament or a State Act in India or an educational institution declared as deemed to be a University under section 3 of the University Grants Commission Act 1956 (3 of 1956) with the experience of two years; or
- (ii) Advanced Diploma or Diploma or Certificate in Fire Engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India or by the Gujarat State Institute for Fire Safety Training (GSIFST), Government of Gujarat or by the Gujarat Institute of Disaster Management (GIDM), Government of Gujarat with the experience of three years; or
- (iii) Post Graduate Diploma or Post Diploma in Fire or Fire & Safety or Fire & Environment, Health & Safety; or Fire Engineering; or Industrial Safety or Industrial Safety & Health from a University established or incorporated by an Act of the Parliament or a State Act in India or an educational institution declared as deemed to be a University under section 3 of the University Grants Commission Act 1956 (3 of 1956) with the experience of three years; or
- (iv) Fellow (FIFireE) or Member (MIFireE) or Graduate (GIFireE) of the Institution

18. In the said Rules, in the SECOND SCHEDULE, -

(i) in para 1, in the Table, in the entry at serial no. 2, in column (2), for the words "Chief Fire Officer", the words "Regional Fire Officer / Chief Fire Officer" shall be substituted;

(ii) in para 2, for sub-para (2), the following sub-para shall be substituted, namely:-

"(2) The staff car used by the Regional Fire Officer or the Chief Fire Officer may display on the bonnet a flag made out of blue black blazer cloth and star plate on front and rear side bumper of the staff car as per drawing."

19. In the said Rules, for the existing THIRD SCHEDULE and FOURTH SCHEDULE, the following schedules shall be substituted, namely:-

"THIRD SCHEDULE

(see sub-rule (1) of rule 14)

List of buildings requiring fire safety certificate

Following is the list of buildings requiring fire safety certificate for compliance of the fire prevention, life safety and fire protection measures:-

- (a) All high rise buildings having height 15 m and above; and
- (b) special buildings, those are,
 - (1) hotel, educational, institutional, business, mercantile, storage, hazardous and mixed occupancies buildings, where any of these buildings have floor area more than 500 m² on any one or more floors;
 - (2) educational buildings having height of 9 m and above;
 - (3) institutional buildings having height of 9 m and above;
 - (4) all assembly buildings;
 - (5) all multilevel car parking;
 - (6) industrial buildings (ANNEXURE B of NBC-2016 Part 4);
 - (i) Light Hazard - having height of 15 m and above
 - (ii) Moderate hazard - covered area more than 500 m²
 - (iii) High hazard - covered area more than 50 m²
 - (7) all hazardous buildings;
 - (8) buildings, having area more than 300m² of incidental assembly occupancy on any floor;
 - (9) buildings with two basements or more, or with one basement of area more than 500 m².

NOTE:

- 1) The definitions and terminology of the terms mentioned in this schedule shall be as per the NBC - 2016 (Part 4).
- 2) Institutional buildings include hospitals, nursing homes, sanatoria, custodial, penal and mental institutions with beds (with or without ICU).
- 3) Industrial buildings having occupancy classified as light hazard as per ANNEXURE B of NBC-2016 (Part 4) below 15 m height of any floor area shall be covered under the provisions of the Factories Act, 1948 and the Rules made thereunder.
- 4) Owner or occupiers of the building or premises not covered under this schedule are advised to provide fire fighting installations as mentioned in Table 7 of the NBC - 2016 (Part 4) in good faith and practice and maintain the same in operational conditions all time.

FOURTH SCHEDULE*(see sub-(4) of rule 21)*

Classification of Buildings, qualification, experience and type of training for Appointment of Fire Safety Officer

1. The Fire Safety Officers of different Grades shall be appointed for different class of buildings namely:

#	Type of Buildings	Fire Safety Officer			
		Grade	Minimum Qualification	Minimum Work Experience	Training Type
1	2	3	4	5	6
1	1. Residential buildings (other than hotels and guest houses) having height more than 15 m but not exceeding 35 m. 2. Hotels upto 15 m in height (floor area exceeding 500 m ² but not more than 1000 m ²). 3. Educational buildings having height more	FSO – G (Fire Safety Officer – General)	Bachelor's or Master's degree in - Fire or Fire & Safety or Fire & EHS; or Fire Engineering OR Bachelor's degree in- Architecture; or Chemical or Civil or Electrical or Mechanical Engineering OR Post Graduate Diploma or Post Diploma in -	0 year 0 year 0 year	Basic Course in Fire Prevention, Life Safety and Fire Protection

#	Type of Buildings	Fire Safety Officer			
		Grade	Minimum Qualification	Minimum Work Experience	Training Type
1	2	3	4	5	6
	<p>than 9 m but not exceeding 15 m.</p> <p>4. Hospitals and Nursing Homes with beds having height less than 15 m with plot area upto 1000 m².</p> <p>5. Custodial, Penal & mental institutions less than 10 meters in height.</p> <p>6. Assembly buildings less than 10 meters in height upto 300 persons, or above 10 meter but not exceeding 15 meter in height.</p> <p>7. Business buildings above 15 m but not exceeding 24 m in height.</p> <p>8. Mercantile occupancies less than 15 m in height and Ground + one storey or more, having total floor area more than 500 m².</p> <p>9. Light Hazard category industrial buildings as per ANNEX-B of the NBC 2016 (Part 4) having height 15m and above.</p> <p>10. Moderate Hazard</p>		<p>Fire or Fire & Safety or Fire & EHS; or Fire Engineering; or Industrial Safety or Industrial Safety & Health</p>		

#	Type of Buildings	Fire Safety Officer			
		Grade	Minimum Qualification	Minimum Work Experience	Training Type
1	2	3	4	5	6
	<p>category Industrial buildings as per ANNEX-B of the NBC 2016 (Part 4) having covered area more than 500 m² and upto 1000 m².</p> <p>11. Mixed Use Occupancies having height more than 9 m upto 15 m.</p> <p>12. buildings with two basements or more, or with one basement of area more than 500 m².</p>				
2	<p>1. Residential buildings (other than hotels and guest houses) having height more than 35 m but not exceeding 60 m in height.</p> <p>2. Hotels upto 15 m in height (floor area more than 1000 m²).</p> <p>3. Hotels 15m and above but not exceeding 30 m in height.</p> <p>4. Educational buildings having height more than 15 m but not exceeding 30 m in height.</p> <p>5. Hospitals and Nursing Homes with beds</p>	FSO – A (Fire Safety Officer – Advance)	Advanced Diploma in fire engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India or having passed MIFireE exam of Institution of Fire Engineers	0 year	Advanced Course in Fire Prevention, Life Safety and Fire Protection
OR			Diploma in fire engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India	0 year	

#	Type of Buildings	Fire Safety Officer			
		Grade	Minimum Qualification	Minimum Work Experience	Training Type
1	2	3	4	5	6
	having height less than 15 m with plot area more than 1000 m ² , or those having height above 15 m upto 24 m.		or having passed GFireE exam of Institution of Fire Engineers		
			OR		
	6. Custodial, Penal & mental institutions more than 10 m but not exceeding 24 m in height.		Certificate in fire engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India.	5 years as sub-officer and above	
	7. Assembly buildings less than 10 m in height having more than 300 persons, or above 15 m but not exceeding 24 m in height.		OR		
	8. Business buildings above 24 m but not exceeding 30 m in height.		Bachelor's or Master's degree in - Fire or Fire & Safety or Fire & EHS; or Fire Engineering	2 year	
	9. Mercantile occupancies above 15 m in height but not exceeding 30 m in height.		OR		
	10. Moderate Hazard category Industrial buildings as per ANNEX-B of the NBC 2016 (Part 4) having covered area more than 1000 m ² .		Post Graduate Diploma or Post Diploma in - Fire or Fire & Safety or Fire & EHS; or Fire Engineering; or Industrial Safety or Industrial Safety & Health	3 years	
	11. Storage buildings below 15 m in height and covered areas		OR		
			Bachelors degree in- Architecture or Chemical or Civil or Electrical or Mechanical Engineering	3 years	

#	Type of Buildings	Fire Safety Officer			
		Grade	Minimum Qualification	Minimum Work Experience	Training Type
1	2	3	4	5	6
	more than 250 m ² , Ground floor or Ground plus more than one floor. 12. Mixed Use Occupancies having height more than 15 m upto 30 m.				
3	<p>1. Residential buildings (other than hotels and guest houses) having height more than 60 meters.</p> <p>2. Hotels exceeding 30 m in height.</p> <p>3. All Starred Hotels.</p> <p>4. Hospitals and Nursing Homes which exceed 24 m but not exceeding 45 m in height.</p> <p>5. Custodial, Penal & mental institutions more than 24 m but not exceeding 30 m in height.</p> <p>6. Assembly buildings above 24 m in height but not exceeding 30 m in height, shopping malls and underground and elevated mass rapid transit systems.</p> <p>7. Business buildings above 30 m in height.</p>	FSO – S (Fire Safety Officer – Specialist)	Advanced Diploma in fire engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India or having passed MIFireE exam of Institution of Fire Engineers	5 years	Specialised course in Fire Prevention, Life Safety and Fire Protection
		OR	Diploma in fire engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India or having passed GIFireE exam of Institution of Fire Engineers	8 years	
		OR	Certificate in fire engineering conferred or awarded by the	10 years as sub-officer and	


#	Type of Buildings	Fire Safety Officer			
		Grade	Minimum Qualification	Minimum Work Experience	Training Type
1	2	3	4	5	6
	8. Underground Shopping centre.		National Fire Service College, Ministry of Home Affairs, Government of India	above	
	9. High Hazard category Industrial buildings as per ANNEX-B of the NBC 2016 (Part 4) having covered area more than 50 m ² .		OR		
	10. Multilevel Car Parking.		Bachelor's or Master's degree in - Fire or Fire & Safety or Fire & EHS; or Fire Engineering	5 years	
	11. Hazardous building upto 15 m in height, single storey or more than one storey.		OR		
	12. Mixed Use Occupancies having height more than 30m.		Post Graduate Diploma or Post Diploma in - Fire or Fire & Safety or Fire & EHS; or Fire Engineering; or Industrial Safety or Industrial Safety & Health	7 years	
	13. Buildings covered under SCHEDULE THREE but not mentioned specifically in this column.		OR		
			Bachelor's degree in - Architecture or Chemical or Civil or Electrical or Mechanical Engineering	7 years	

Note:

1. Unless specified otherwise, the minimum educational qualification shall be from a University established or incorporated by an Act of the Parliament or a State Act in India or an educational institution declared as deemed to be a University under section 3 of the University Grants Commission Act, 1956 (3 of 1956).
2. Work experience, wherever applicable, shall be in field of Fire Prevention, Life Safety and Fire Protection measures, Fire systems design/ installation, Fire safety consultancy and Fire related inspections/ audits.

3. FSO-A can also take up work of renewal of fire safety certificate for type of buildings mentioned against FSO-G.
 4. FSO-S can also take up work of renewal of fire safety certificate for type of buildings mentioned against FSO-A and FSO-G.
- 2. The duties of the fire safety officer shall be:-**
1. Issue fire safety certificate renewal upon compliance of all the mandatory requirements.
 2. Give bi-annual declaration that fire prevention, life safety and fire protection measures provided in the building or premises are operational, in place and in efficient working condition.
 3. Carry out bi-annual emergency mock drills and maintain record of the same. During the mock drill, provide basic information to occupiers and other security/maintenance staff with respect to basic fire prevention, fire-fighting and related aspects.
3. Mode and format of providing training to persons for being eligible to enroll as FSO shall be as notified by the State Government from time to time. ”

By Order and in the name of Governor of Gujarat,



(R. H. Vasava)

Deputy Secretary to Government.

Copy of the revised notification issued by State Fire Prevention Services, Gujarat,
dated 22.01.2022



सत्यमेव जयते

WE SERVE TO SAVE

રાજ્ય અગ્નિ નિવારણ સેવાઓની કચેરી

બલોડ નં.૧૩, ત્રીને માળ, ડો.ઇવરજી મહેતા ભવન, ગાંધીનગર-૩૮૨૦૧૦.

ઇમેલ: dir.sfps@gmail.com, ટેલીફોન નં. ૦૭૮-૨૩૨-૫૭૦૨૨/૨૩/૪૦



ક્રમાંક: સફસ/ફન-૮૫.૧/૫૫/૨૦૨૨

તા.૧૨/૦૧/૨૦૨૨

વિષય: ફાયર સેફ્ટી સર્ટીફિકેટ (NOC) ઇશ્યુ કરવા બાબત.

વંચાણ:- શહેરી વિકાસ અને શહેરી ગૃહ નિર્માણ વિભાગના પત્ર ક્રમાંક:-અગન-૧૦૨૦૨૧-૧૦૦-૯૧,
તા.૧૧/૦૧/૨૦૨૨.

પરીપત્ર:-

સરકારશ્રીના શહેરી વિકાસ અને શહેરી ગૃહ નિર્માણ વિભાગના પત્ર ક્રમાંક:- અગન-૧૦૨૦૨૧-૧૦૦-૯૧, તા.૧૧/૦૧/૨૦૨૨ના પત્ર દ્વારા આજ્ઞાનુસાર જણાવવાનું કે, ગુજરાત અગ્નિ નિવારણ અને જીવન સુરક્ષા ઉપાય વિષયક નિયમો, ૨૦૧૪ સુધારવા સારૂ ગુજરાત અગ્નિ નિવારણ અને જીવન સુરક્ષા ઉપાય વિષયક (સુધારા) નિયમો ૨૦૨૧ તા.૨૨/૦૧/૨૦૨૧ના જાહેરનામા નં.GH/V/9 of 2021/AGN-102021-100-L1થી બહાર પાડવામાં આવેલ છે. જેમાં નિયમ ૨૪ અને નિયમ ૨૫ સબસ્ટીટ્યુટ કરવામાં આવેલ છે. જે મુજબ આ જાહેરનામાની તારીખ પછીથી ઇશ્યુ થયેલ તમામ નવી ફાયર સેફ્ટી સર્ટીફિકેટ(એન.ઓ.સી)ની વેલીડીટી ૩ (ત્રણ) વર્ષ અને રીન્યુઅલ ફાયર સેફ્ટી સર્ટીફિકેટ(એન.ઓ.સી)ની વેલીડીટી ૨ (બે) વર્ષ ગણવાની રહેશે. જે આજ્ઞાનુસાર સુચના આપવામાં આવે છે.

નિયામક

સ્ટેટ ફાયર પ્રિવેન્શન સર્વિસીસ,
ગુજરાત રાજ્ય, ગાંધીનગર.

પ્રતિ,

- (૧) સર્વે ચીફ ફાયર ઓફિસરશ્રી, મહાનગરપાલિકા.
- (૨) સર્વે રીજીયોનલ ફાયર ઓફિસરશ્રી, રાજ્ય અગ્નિ નિવારણ સેવાઓની કચેરી.

નકલ સવિનય રવાના:-

- (૧) અગ્ર સચિવશ્રી, શહેરી વિકાસ અને શહેરી ગૃહ નિર્માણ વિભાગ, સચિવાલય, ગાંધીનગર તરફ નમ્ર જાણ સારૂ.
- (૨) સર્વે મ્યુનિસિપલ કમિશ્નરશ્રીઓ, મ્યુનિસિપલ કોર્પોરેશન જાણ તથા જરૂરી કાર્યવાહી સારૂ.
- (૩) કમિશ્નરશ્રી, મ્યુનિસિપાલિટીઝ એડમીનીસ્ટ્રેશન, ગુજરાત સ્ટેટ, ગાંધીનગર જાણ તથા જરૂરી કાર્યવાહી સારૂ.
(સર્વે રીજીયોનલ મ્યુનિસિપાલિટીઝ કમિશ્નરશ્રીઓ તથા ચીફ ઓફિસર, મ્યુનિસિપાલિટીઝને પરિપત્રીત કરવા વિનંતી સહ)